

# Meeting Record

Project Name (Case numbers)	Meeting Chair	Meeting Date
MUP 12-007 Soitec Rugged Solar	René Vidales	6/22/12

## Action Items:

Action to be taken:	Responsible Party	Due date
1.A Drainage Study with the items requested below will be submitted	AECOM	Next submittal
2.		
3.		
4.		
5.		
6.		

## Decisions:

Decisions/Agreements reached:
1. Legible drainage exhibits at least 24"x36" in size will be provided in the Drainage Study, including an overall exhibit as well as broken down (larger scale) exhibits for both offsite and onsite. The Preliminary Grading Plan does not have to be included in the Drainage Study.
2. A table listing all crossings (location/node number, type of crossing, 100-year design flow, flow depth, crossing width, etc.) will be provided on both the Drainage Study and the Preliminary Grading Plan.
3.Crossing Detail(s) will be included in the Drainage Study and Preliminary Grading Plan.
4. Limits of inundation from the 100-year storm will be shown for Tule Creek, including Rough Acres Ranch Road and any other areas that are proposed to be re-graded with solar panels installed.
5. A discussion shall be included in the report to account for possible scour from the solar panel bases

Copy of Record provided to all?	Results of meeting summarized?	Signature of meeting chair
Yes	Yes	René Vidales

Project Name (Case numbers)	Meeting Chair	Meeting Date
MUP 12-007 Soitec Rugged Solar	René Vidales	6/22/12

## Attendance Roster

[illegible]